




Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



NOTIFIED BODY EU TYPE EXAMINATION CERTIFICATE		Certificate N° 19/FR/4478-0-REV 0
In accordance with module B "Production Type" of the Pressure Equipment Directive 2014/68/EU		
Manufacturer	Name	EUROFEU
	Address	Rue Albert Rémy FR - 28250 SENONCHES FRANCE
Concerned Equipment : Portable Stored Pressure Fire Extinguishers		
Type : 1-2- 6-9 L AVD /6-9KG/L PERFEX II according to technical design file ref. AVD/PERFEX II rev 00		
Capacities :	1L – 2L	6kg/L – 9kg/L
Set pressure :	max. at 60 C°: 18.8 bar	20 bar
Test pressure :	27 bar	29 bar
Service temperature range : min. -30°C/ max. + 60°C (see label)		
The manufacturer is allowed to affix the CE Mark to the approved equipment under the conditions described in article 19 of the Directive, and only if the requirements stated in module D are fully met.		
The approval is valid until 18/03/2029		
APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/68/UE, certifies that the design of these pressure vessels conforms to the relevant requirements of the pertinent EN 3, standards in force and the Pressure Equipment Directive 2014/68/EU on basis of the documentation and samples supplied for review and approval.		
Date of first issue : 18/03/2019	Name : Ch. Leplat	Position General Manager
Notified body identification number : 0029	Signature 	
Notified body stamp :	APRAGAZ Belgium Inspecting Authority	
Notified body reference :	0106/P4629/PED27	