

Manufacturer:

OGNIOCHRON S.A.

ul. Przemysłowa 42, 34-120 Andrychów, Poland  
tel.: +48 33 875 10 70 ext. 161, e-mail: export@ogniochron.eu

www.ogniochron.eu

# ogniochron

## Application

Designed for protection of community buildings, office rooms, production facilities, warehouses for flammable liquids, airports. Comparing to powder extinguishers, foam extinguishers are more ecological and cleaning of compartments after usage extinguishing agent is much easier.



## Basic features

- Easy and ergonomic in operation.
- Fast and effective in extinguishing.
- Economical maintenance and service.
- Cut-off valve behind the pressure indicator makes control of fire extinguisher easier.
- Construction of the valve enables temporary interruption of extinguishing.
- Possibility of multiple refilling.
- Cylinder of fire extinguisher covered with polyester paint, resistant to UV radiation.
- Interior of cylinder protected with anticorrosive layer.


## Quality and safety

Manufactured according to requirements of domestic and EU markets on the basis of certified quality system ISO 9001. Fulfills requirements of European Standard EN3 and Safety Directive PED 2014/68/UE.



## Technical data

Extinguishing efficiency	27A 144B
Weight of extinguishing agent	6 l
Working agent	N <sub>2</sub>
Operation time	min. 15 s
Cylinder test pressure	27 bar
Operation pressure	15 bar
Operating temperature	0 °C/+60 °C
Total weight	~9,3 kg
Fire under voltage	1000 V
Total height (A)	501 mm
Cylinder diameter (B)	160 mm



## Fluorine-free foam extinguisher

# GPN-6x AB/FF

**FLUORINE FREE**



**ogniochron**  
**FIRE EXTINGUISHER**  
6 LTR OF FIRE EXTINGUISHING AGENT AB  
27A 144B

**1** PULL OUT PIN.  
**2** AIM HOSE AT BASE OF FIRE AND PRESS LEVER. USE IN UPRIGHT POSITION.

**CAN BE USED FOR EXTINGUISHING OF ELECTRIC DEVICES UP TO 1000 V. KEEP THE DISTANCE MIN. 1 M**

INSPECTION SHOULD BE MADE EVERY 12 MONTHS AT LEAST. USE ONLY SPARE PARTS IN ACCORDANCE WITH APPROVED SAMPLE OF FIRE EXTINGUISHER.  
**REFILL FIRE EXTINGUISHER AFTER EACH USAGE!**

EXTINGUISHING AGENT: 6 L ROBU FF1500  
PROPELLANT: NITROGEN 25 bar AT TEMP. +20 °C  
SCOPE OF APPLICATION TEMPERATURES: 0 °C TO +60 °C

CERTIFICATE NO. MPA SP 39/23 ACC. DIN-EN 3-7  
TYPE: GPN-6x AB/FF

Manufacturer: **OGNIOCHRON S.A.**  
ul. Przemysłowa 42, 34-120 Andrychów, POLAND  
tel.: +48 33 875 10 70  
e-mail: export@ogniochron.eu, www.ogniochron.eu

CE 0062

Year of production: 2023 2024 2025 2026 2027 2028