

MOBIAK S.A. is certified according to the following Quality Management systems and Maritime Services:



**I-Net**  
HEALTH & SAFETY MANAGEMENT SYSTEM  
OHSAS 18001:2007  
QA-C-510B/12



**TÜVRheinland®**  
**CERT**  
ISO 14001



ISO 9001:2008  
Cert No37939



**RINA**  
SERVICE RECOGNITION  
11XKH0701



**CODE: MBK17-020FC-VR**

## 2Lt ABF Fire Extinguisher with metallic bracket

Portable

2Lt ABF - Wet Chemical Fire Extinguisher. With internal plastic layer and Pressure Gauge Safety Release Valve.



### Characteristics

Capacity	2Lt
Fire Performance	5A 34B 40F
Extinguishing agent	Wet Chemical
Operating Temperature	0°C to +60°C
Max allowable pressure	17bar
Test Pressure	30bar
Volume of Equipment	2,4 Lt
Cylinder height	311±2mm
Cylinder diameter	110 ± 2 mm
Cylinder neck thread	30 x 1,5
Cylinder material	DC03 / DC04
Valve material	CuZn40Pb2
Safety valve	22-27 bar
Approx. dimensions	128x128x385mm
Paint finish	RAL 3000
Packing details	Individual packaging



Issue Date: 05/05/2017

Information may change



FACTORY: AKROTIRI, CHANIA, P.C.: 73100, TEL.: +30 2821063222, FAX: +30 28210 66260

CENTRAL EXHIBITION: 96-98 M. MPOTSARI str. P.C.: 73136, CHANIA, GREECE, TEL.: +30 28210 91561, FAX: +30 28210 91644

ATHENS DISTRIBUTION CENTER: MAGOULA - ASPROPIRGOS, P.C.: 19300, TEL.: +30 210 4614006, FAX: +30 210 5595986

N.GREECE DISTRIB. CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C.: 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENT. & EAST CRETE DISTRIB. CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE, P.C.: 71601, TEL./FAX: +30 2810 333151

web site: [www.mobiak.gr](http://www.mobiak.gr)

email: [info@mobiak.gr](mailto:info@mobiak.gr)