

MOBIAK S.A. is certified according to the following Quality Management systems and Maritime Services:



I-Net
HEALTH & SAFETY MANAGEMENT SYSTEM
OHSAS 18001:2007
QA-C-510B/12



TÜVRheinland®
CERT
ISO 14001



ISO 9001:2008
Cert No37939



RINA
SERVICE RECOGNITION
11XHX0701



CODE: MBK17-050CA-VR

Fire Extinguisher 5Kg CO₂ Portable

Fire Extinguisher 5Kg CO₂. Metallic bracket included.



Characteristics

Capacity	5Kg
Fire performance	89B
Extinguishing agent	Carbon Dioxide (CO ₂)
Operating temperature	-30°C to 60°C
Max allowable pressure	216 bar
Test pressure	310bar
Volume of equipment	7,50Lt
Cylinder height	600±6mm
Cylinder diameter	136,5x1,37mm
Cylinder neck thread	25E
Cylinder material	CuZn40Pb2
Valve material	HPb59-1
Safety valve	240-280 bar
Approx. gross weight	13,84Kg
Approx. Dimensions	220x150x790mm
Paint finish	RAL 3000
Packing details	individual packaging



Issue Date: 05/05/2017

Information may change



FACTORY: AKROTIRI, CHANIA, P.C.: 73100, TEL.: +30 2821063222, FAX: +30 28210 66260

CENTRAL EXHIBITION: 96-98 M. MPOTSARI str. P.C.: 73136, CHANIA, GREECE, TEL.: +30 28210 91561, FAX: +30 28210 91644

ATHENS DISTRIBUTION CENTER: MAGOULA - ASPROPIRGOS, P.C.: 19300, TEL.: +30 210 4614006, FAX: +30 210 5595986

N.GREECE DISTRIB. CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C.: 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENT. & EAST CRETE DISTRIB. CENTER: P¹ str. INDUSTRIAL ZONE OF HERAKLION - CRETE, P.C.: 71601, TEL./FAX: +30 2810 333151

web site: www.mobiak.gr

email: info@mobiak.gr