



HEALTH & SAFETY MANAGEMENT SYSTEM
OHSAS 18001:2007
QA-C-510B/12



TÜVRheinland®
CERT
ISO 14001



ISO 9001:2008
Cert No 37939



RINA
SERVICE RECOGNITION
11KH0701



CODE:

MBK15-WN-9

ERP:

0135372

Fire Extinguisher 9Lt Water Mist Portable

Fire Extinguisher 9Lt Water Mist with one seam vessel with INTERNAL PLASTIC LAYER and Pressure Gauge Safety Release Valve.



Characteristics

Capacity	9Lt
Fire performance	21A 40F
Extinguishing agent	Water
Operating temperature	+5°C to +60°C
Average discharge time	70,1 sec
Max allowable pressure	20bar
Test pressure	30bar
Volume of equipment	13,2 Lt
Cylinder height	534 ± 2 mm
Cylinder diameter	190 ± 2 mm
Cylinder neck thread	30 x 1.5 mm
Cylinder material	DC03/DC04
Valve material	HPb59-1
Valve safety	19-26 bar
Approx. gross weight	14,8 Kg
Approx. dimensions	640 x 200 mm
Paint finishing	RAL 3000
Packing details	Carton Atomic Packing



FACTORY: AKROTIRI, CHANIA, P.C.: 73100, TEL.: +30 2821063222, FAX: +30 28210 66260

CENTRAL EXHIBITION: 96-98 M. MPOTSARI str. P.C.: 73136, CHANIA, GREECE, TEL.: +30 28210 91561, FAX: +30 28210 91644

ATHENS DISTRIBUTION CENTER: MAGOULA - ASPROPIRGOS, P.C.: 19300, TEL.: +30 210 4614006, FAX: +30 210 5595986

N.GREECE DISTRIB. CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C.: 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENT. & EAST CRETE DISTRIB. CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE, P.C.: 71601, TEL./FAX: +30 2810 333151

web site: www.mobiak.gr

email: info@mobiak.gr