

MOBIAK S.A. is certified according to the following Quality Management systems and Maritime Services:



I-Net
HEALTH & SAFETY MANAGEMENT SYSTEM
OHSAS 18001:2007
QA-C-510B/12



TÜV Rheinland
CERT
ISO 14001



ISO 9001:2008
Cert No37939



RINA
SERVICE RECOGNITION
11X10701



CODE: MBK17-090AF-VR

Fire Extinguisher 9 Lt Foam Portable

Fire Extinguisher 9Lt Foam with Internal plastic layer and Pressure Gauge Safety Release Valve.



Characteristics

Capacity	9Lt
Fire Performance	27A 183B
Extinguishing agent	Foam
Operating temperature	+5°C to +60°C
Max allowable pressure	18 bar
Test pressure	27 bar
Volume of equipment	11,5Lt
Cylinder height	528±2mm
Cylinder diameter	180±1mm
Cylinder neck thread	M45x1,5
Cylinder material	St14
Valve material	CuZn40Pb2
Safety valve	19-26 bar
Approx. gross weight	14,2 Kg
Approx. dimensions	195x195x635mm
Paint finish	RAL 3000
Packing details	Individual packaging



Issue Date: 05/05/2017

Information may change



FACTORY: AKROTIRI, CHANIA, P.C.: 73100, TEL.: +30 2821063222, FAX: +30 28210 66260
CENTRAL EXHIBITION: 96-98 M. MPOTSARI str. P.C.: 73136, CHANIA, GREECE, TEL.: +30 28210 91561, FAX: +30 28210 91644
ATHENS DISTRIBUTION CENTER: MAGOULA - ASPROPIRGOS, P.C.: 19300, TEL.: +30 210 4614006, FAX: +30 210 5595986
N.GREECE DISTRIB. CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C.: 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793
CENT. & EAST CRETE DISTRIB. CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE, P.C.: 71601, TEL./FAX: +30 2810 333151
 web site: www.mobiak.gr email: info@mobiak.gr