

MOBIAK S.A. is certified according to the following Quality Management systems and Maritime Services:



**I-Net**  
HEALTH & SAFETY MANAGEMENT SYSTEM  
OHSAS 18001:2007  
QA-C-510B/12



**TÜVRheinland®**  
**CERT**  
ISO 14001



ISO 9001:2008  
Cert No37939



**RINA**  
SERVICE RECOGNITION  
11KH0701



**CODE: MBK17-120PA-VR**

## Fire Extinguisher 12Kg Dry Powder with metallic bracket

### Portable

Fire Extinguisher 12Kg Dry Powder with Pressure Gauge Safety Release Valve.  
Metallic bracket included.



#### Characteristics

Capacity	12Kg
Fire Performance	55A 233B C
Extinguishing Agent	HJ ABC Universal
Operating Temperature	-30°C to 60°C
Max allowed Pressure	17bar
Test Pressure	30bar
Volume of Equipment	13,88Lt
Cylinder Height	623±2mm
Cylinder diameter	180 ± 1 mm
Cylinder neck thread	30 x 1.5
Valve material	St14
Cylinder material	CuZn40Pb2
Safety valve	22-27 bar
Approx. gross weight	17,84Kg
Approx. dimensions	190x190x725mm
Paint finish	RAL 3000
Packing details	individual packaging



Issue Date: 05/05/2017

Information may change



**FACTORY: AKROTIRI, CHANIA, P.C.: 73100, TEL.: +30 2821063222, FAX: +30 28210 66260**  
**CENTRAL EXHIBITION: 96-98 M. MPOTSARI str. P.C.: 73136, CHANIA, GREECE, TEL.: +30 28210 91561, FAX: +30 28210 91644**  
**ATHENS DISTRIBUTION CENTER: MAGOULA - ASPROPIRGOS, P.C.: 19300, TEL.: +30 210 4614006, FAX: +30 210 5595986**  
**N.GREECE DISTRIB. CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C.: 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793**  
**CENT. & EAST CRETE DISTRIB. CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE, P.C.: 71601, TEL./FAX: +30 2810 333151**  
 web site: [www.mobiak.gr](http://www.mobiak.gr) email: [info@mobiak.gr](mailto:info@mobiak.gr)